



Product Service

Attestation of Conformity

No. N8A 098238 0038 Rev. 00

Holder of Certificate: HANYOUNG NUX CO., LTD.

28, Gilpa-ro 71beon-gil, Nam-gu
Incheon 22121
REPUBLIC OF KOREA

Product: Controller
(Power Regulator)

Model(s): TPR-2G70H, TPR-2G50H, TPR-2G35H,
TPR-2G25H

Parameters:

Rated operational voltage U _e (V):	380 VAC
Rated frequency:	50/60 Hz
Rated operational current I _e (A):	70 A(TPR-2G70H), 50 A(TPR-2G50H), 35 A(TPR-2G35H), 25 A(TPR-2G25H)
Rated impulse withstand voltage U _{imp} (kV):	6 kV
Kind of current:	a.c.
Rated control circuit voltage U _c (V):	1-5 VDC
Utilization category:	AC-51
IP code:	IP00
Pollution degree:	3

Tested according to: EN 60947-4-3:2014
EN 60947-1:2007/A2:2014

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA01318019

Date, 2020-01-15


(Harry Kwon)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®